DRAFT Feasibility Assessment of Biomass Heating and Cooling at Plumas NF Supervisor's Office

Quincy, California

July 2013



Prepared for: Plumas National Forest US Forest Service

On behalf of: Sierra Institute for Community and Environment 4438 Main Street Taylorsville, CA 95983 (530) 284-1022

Prepared By:



Wisewood, Inc. 1001 SE Water Avenue, Suite 255 Portland, OR 97214 (503) 608-7366

July 2013

Quincy Supervisor's Office: Existing Heating Systems

The USFS Quincy Supervisor's Office is a combined office/equipment maintenance complex with multiple buildings located at 159 Lawrence Street, Quincy, California. A total of nine buildings were toured on June 24, 2013, including: Main Office (building #2000); Dispatch (#2301); Maintenance Garage (#2101); Garage/Vehicle Wash (#2100); Workshop/Engineering (#2300); Storage (#2202); Warehouse (#2201); Engineering (#2200); and Natural Resources Office (#2001).

Main Office (#2000)

The Main Office is a large building with 2 stories on its west wing and a single story and basement on its east wing. The east wing has three identical Lennox Elite Series oil-fired furnace/DX split systems fired by Lennox AFII-150 oil burners in its basement boiler room, each heating one of three zones across the wing that is controlled by its own thermostat. Each furnace is also connected to a Bryant air conditioning unit located outside the building. One of the furnaces (the middle unit) has been in need of constant repair. Site maintenance staff believe it is related to the fact that the main lobby and conference room are controlled by a shared thermostat, which creates comfort issues for the staff and puts large amounts of pressure on the system with constant thermostat changes.

Staff complaints include a lack of room-by-room temperature control. Heating vents in the building have fixed louvers to prevent back pressure in the system from closed louvers; however, to increase comfort, staff members regularly cover the vents completely, negating any benefits of the open louver vents, and potentially straining the furnace blower and causing burner problems.

The basement experiences minor flooding regularly due to groundwater seepage and there is no active ventilation system for the building (although its 1930s construction allows for considerable passive air movement). There is also concern over a presumed leak in the diesel fuel tank on the north side of the building, just outside the furnace room. The 1,000-gallon fuel oil tank shows visible signs of wear, and is due for replacement or removal.

The west wing has four identical Bryant Plus 90 propane-fired split furnace/A/C units rated at 128,000 BTU/hour (output) and are located in each of the four bathrooms in the wing (one per floor at each end of the wing). Each furnace serves its own heating zone. Four Bryant Model 563C-060 air conditioners (5.0 tons at SEER 12.0) provide cooling for each split system. A Reliance 30-gallon electric domestic water heater located in a janitor's closet provides hot water to each of the bathrooms across the building. All heat and cool air distribution is via forced air throughout the building.

July 2013

Dispatch (#2301)

The Dispatch building has three sections: the main dispatch offices; a server room; and its training and auxiliary offices. The main dispatch offices are heated by two independently controlled electric wall units. An International Comfort Products Model CA5536VKD2 air conditioning unit (3 tons) at the south side of the building provides cooling to the main dispatch offices via forced air vents in the office floor.

The server room (which Wisewood was not given access to) has its own power and cooling sources. Two Lennox Model HS16-411v-4p (Est. rating 3.5 ton) air conditioners located at the back of the building provide cooling to the 85 square foot space.

The training area and additional offices are heated and cooled with thru-wall heat pump units that are independently controlled. The training area is generally only used 30-60 days per year and so is not a large heat load.

A 1,150-gallon propane tank sits centrally in the parking lot in front of the Dispatch building, to the east.

Maintenance Garage (#2101)

The Maintenance Garage is a long building with a large, open workshop area heated by two Dayton Model 3E383A ceiling-mounted propane-fired heating units (100 MBH rated output) and a smaller area (about one third of the building) containing offices and storage. The office space is heated by an unknown model Day and Night brand furnace. It has a domestic hot water heater with a capacity of _____. Cooling is provided by a Lennox air conditioner (model HS16-411v-4p, rated at 3.5 ton) located on the north side of the building.

Garage/Vehicle Wash (#2100)

The Garage and Vehicle Wash building is divided into two spaces. The south side contains the vehicle wash room with a single Modine (assumed 100 MBH) ceiling-mounted heater fired by propane. The adjacent heavy equipment storage area is not climate controlled.

The north end of the building houses a large storage space and offices. It is heated by a propane-fired furnace (unknown make and model) via forced air and cooled by a Lennox air conditioning unit (HS19-311V-4P, 2.5 ton) located on the south side of the building.

July 2013

Workshop/Engineering (#2300)

The Workshop is divided into three open spaces: an old tire shop/storage on the southwest corner with no climate control; a large fire storage space on the east side with no climate control; and a central road crew shop/heavy equipment storage space on the northwest side of the building. This road crew shop is heated by one ceiling-mounted Dayton Fuel-Trimmer (100 MBH) propane-fired heating unit and one wood stove burning cordwood. There is no plumbing in the building and no cooling.

A 1,154-gallon propane tank sits behind the Workshop on its south side.

Storage (#2202)

Wisewood was not given access to the Storage building, but was informed by maintenance staff that it is heated by four ceiling-mounted heating units (assumed 100 MBH each) fired by propane (one in each of the four building sections). There is no cooling and no plumbing in the building.

A 460-gallon propane tank sits to the east of the Storage building along the edge of the overflow parking lot.

Warehouse (#2201)

The Warehouse's main storage area is heated by a single ceiling-mounted Dayton Fuel-Trimmer (100 MBH) propane-fired heating unit and does not have cooling. The small office space at the south end of the building is heated by another single Dayton propane-fired heating unit mounted on the ceiling. Cooling is provided by a single wall-mounted air conditioning unit.

A 499-gallon propane tank sits between the Warehouse and Engineering buildings, to the east side.

Engineering (#2200)

The Engineering building is heated by a Xenon 24.5" furnace fired by propane. It is cooled by a Goodman air conditioner (estimated at 2.5 tons). Domestic hot water is assumed to be provided by a small electric hot water heater in the rest rooms.

Natural Resources Office (#2001)

The Natural Resources Office is heated by a oil-fired furnace (unknown make and model) located in the basement. It is cooled by two air conditioning units, one Rheem and (Model 13AJA60A01757, rated at 5 tons) one International Comfort Products (estimated at 5 tons) . Domestic hot water is heated by a single 6-gallon hot water heater, also located in the basement. A 250-gallon fuel oil (diesel) tank sits behind the building on the east side.

July 2013

Energy Use

From January to December of 2010, the Supervisor's Office in Quincy used 10,475 gallons of propane at a cost of \$23,208 (an average price of \$2.22/gallon). In 2011, this increased to 11,506 gallons of propane at a cost of \$29,257 (an average price of \$2.54/gallon).

In the fall (October-December) of 2011, the Supervisor's Office used 1,775 gallons of #2 fuel oil (diesel) at a cost of \$6,471 (an average price of \$3.65/gallon). In 2012, a total of 3,266 gallons of fuel oil were used at a cost of \$12,407 (an average price of \$3.80/gallon). In the winter and spring of 2013 (January-May), 2,010 gallons of fuel oil were used at a cost of \$7,750 (an average price of \$3.85/gallon).

Proposed Biomass Heating and Cooling Scenarios

Wisewood assessed two scenarios for provided heating and cooling from biomass to some or all of the buildings at the Plumas NF Supervisor's Office facility.

Scenario 1: Campus Wide Heating and Cooling

Scenario 1 aims to cover all heating and cooling loads at the Supervisor's Office with a combined biomass boiler and water-fired chiller. The model assumes that the heating energy replaced includes all propane and heating oil consumed on-site. Cooling energy to be replaced is currently assumed to be 30,000 kWh/yr, and requires further verification.

A centrally-located boiler/chiller would provide hot water and chilled water via underground pipes (4-pipe) to new air handlers in each of the conditioned spaces on the SO campus. A 4-pipe system (separate hot water and chilled water distribution piping) would allow for simultaneous heating and cooling of different buildings at the SO campus, which is something that occurs with the existing system, based on interviews with occupants. While this could cause inefficiencies if both heating and cooling energy are applied to different zones of the same building at the same time, different buildings have widely varying thermal comfort profiles, and the ability to provide heating and cooling simultaneously could be advantageous. A site map showing one proposed boiler location and pipe layouts is included at the end of the report narrative, before site photos.

Alternately, a 2-pipe system could supply both hot and chilled water to each of the conditioned spaces, with a twice per year seasonal changeover from heating to cooling. This would enable significant cost savings on distribution pipe installation and possible controls as well.

July 2013

To meet the heat demand from all of the Supervisor's Office nine buildings, a biomass boiler rated at 750 MBH would cover 90% of heating needs. This means that a new propane-fired "peaking" and low-load boiler would meet 10% of annual heat demand, on average; most of this demand would be incurred on extremely cold ("peak") days and on "shoulder" seasons, when outside temperatures are still cool, but heat is only required for a few hours in the morning or evening. During these times, a propane or oil boiler can be a more efficient heat source, as they can fire up and down within minutes, whereas the biomass boiler system may require up to an hour to warm up.

To meet the estimated cooling demand from all nine buildings, a water-fired chiller rated at 240 MBH would cover 87% of cooling needs, with existing electric air conditioners or new compression chiller meeting the remaining 13% of cooling needs. In a 4-pipe system, concurrent cooling/heating is possible, allowing some zones to be chilled while others remained heated. In a 2-pipe system, the system would supply either heating or cooling exclusively. With this option, the cooling demand would only require the biomass boiler's low-fire setting to run.

Scenario 1 Energy Savings

Fossil energy savings: 1,339 MMBtu/yr

Biomass utilization: 116 tons/yr

The Quincy Supervisor's Office can expect to use approximately 116 tons of wood fuel per year (based on local heating degree day data) at a total cost of \$11,576, assuming wood \$100/green ton and 25% moisture content. The continued use of fossil fuel during peak loads and shoulder seasons will cost approximately \$3,956. Total heating and cooling fuel costs will be reduced by approximately 81%.

Scenario 2: Main Buildings (2000, 2001, 2200, 2301), Heating Only

Scenario 2 aims to cover only the heating loads of buildings 2000, 2001, 2200, 2301 at the Supervisor's Office with a biomass boiler system. Heating energy replaced includes 80% of the propane and all heating oil consumed on-site.

A centrally-located boiler would provide hot water via underground pipes (2-pipe) to new air handlers in each of the conditioned spaces on the Supervisor's Office campus. The existing cooling systems would be retained. A site map showing one proposed boiler location and pipe layouts is included at the end of the report narrative.

To meet the heat demand from the Supervisor's Office main buildings (numbers 2000, 2001, 2200, and 2301), a biomass boiler rated at 500 MBH would cover 91% of heating needs. This means that a secondary fossil fuel boiler would meet 9% of heat demand, on average; most of this demand is represented on extremely cold ("peak") days and on "shoulder" seasons.

July 2013

Scenario 2 Energy Savings

Fossil energy savings: 1,186 MMBtu/yr

Biomass utilization: 102 tons/yr

The Quincy Supervisor's Office can expect to use approximately 102 tons of wood fuel per year in this scenario (based on local heating degree day data) at a total cost of \$10,188. The continued use of the existing propane and oil boilers during peak loads and shoulder seasons will cost approximately \$2,896. Total heating and cooling fuel costs will be reduced by approximately 81%.

Technology Assessed

The technology assessed includes a biomass boiler capable of utilizing small, dry wood chips (2" minus, 35% moisture content or less) with a thermal energy storage tank, and in the case of the water-fired chiller, a lithium-bromide single-effect water fired chiller is assumed.

The assessment assumes state-of-the-art biomass boiler systems that incorporate full automation of all major functions, including automatic ignition, unattended modulating operation, and automatic de-ashing. Additionally, the system would have the components required for consistently low emissions levels with variable quality fuels: an oxygen sensor and flue gas temperature sensor-based combustion control system; distinct primary and secondary combustion zones; and flue gas recirculation.

The system performance and cost estimates are based on modern, high efficiency boilers with a proven track record, requiring only minimal work to maintain or adjust when fuel conditions change. The system cost estimates also assume that a new prefabricated boiler house and fuel storage system would be built as a stand-alone structure, with associated slab construction and trenching costs.

Site Considerations

A new 10-year Master Plan that is currently being evaluated may include recommendations that a new building be constructed on the site to replace most of the existing infrastructure and consolidate offices. The Main Office could be required to remain, as it is vintage 1930s and may come under protection of the California State Historic Preservation Office (SHPO) rules.

There are several viable options on the Supervisor's Office site for placing a biomass boiler. One ideal location is the seven-car garage in the center of the main parking lot. Another ideal location is the northeast corner of the property in the overflow parking lot, making potential interconnection to Quincy High School feasible via the an adjacent pedestrian pathway.

July 2013

According to maintenance staff, there is a large oil spill around the 1,150-gallon propane tank in the central parking lot near the Dispatch building. The spill was monitored for 15 years and found not to migrate, so it has not been mitigated. Should construction require that site soils be removed, it may require permitting, testing, or other measures.

Financial analysis

For both scenarios considered, the following data were used: an escalation rate for fossil fuels (oil and propane) of 5.8% (based on US DOE EIA commerical propane price data); an escalation rate for wood fuels of 2.0%; and an escalation rate of 2.0% for electricity. The total installation costs include, but are not limited to: project development and management; design and engineering; permitting; equipment; labor; interconnection with existing systems; site work; concrete; building installation; commissioning; 10% unlisted items allowance; and 11% contingency allowance.

The total cost of installation of Scenario 1 is estimated to be \$1.36 million. The payback on this system based on fuel savings is approximately 25 years. Annual operating costs will be reduced by over 52% in the first year, growing to an estimated 75% operating savings by year 30 as fossil fuel prices continue to rise at a faster rate than woody biomass fuels.


The total cost of installation of Scenario 2 is estimated to be \$900,000. The payback on this system based on fuel savings is approximately 20 years. Annual operating costs will be reduced by over 55% in the first year, growing to an estimated 79% operating savings by year 30.

These costs may be partially offset by additional incentives through state and federal tax credits, grants, or low- and no-interest loans.

Recommendations

Before a final biomass boiler design is considered, the USFS should decide what energy efficiency measures it may take in the near future (window replacement, insulation, lighting retrofits, etc.) so that the boiler can be sized to match the resultant decrease in energy demand. This is especially true for any potential Master Plan that may include new construction, which would drastically alter the energy use profiles and recommended boiler placements.

Scenario 1 Proposed Boiler Location and Pipe Layout (heating and cooling for all campus buildings)



Scenario 2 Proposed Boiler Location and Pipe Layout (heating only for four buildings)



July 2013


Site Photos

Main Office (#2000)



East wing







DRAFT Feasibility of Biomass Heat for USFS – Quincy Supervisor's Office July 2013



July 2013

West wing









DRAFT Feasibility of Biomass Heat for USFS – Quincy Supervisor's Office July 2013





July 2013





July 2013

Dispatch (#2301)











DRAFT Feasibility of Biomass Heat for USFS – Quincy Supervisor's Office July 2013







July 2013

Maintenance Garage (#2101)





July 2013





July 2013







July 2013

Garage/Vehicle Wash (#2100)





July 2013







July 2013

Workshop/Engineering (#2300)







July 2013

Storage (#2202)



July 2013

Warehouse (#2201)







July 2013

Engineering (#2200)







July 2013






July 2013

Natural Resources Office (#2001)










DRAFT Feasibility of Biomass Heat for USFS – Quincy Supervisor's Office July 2013



July 2013





All photos: Wisewood, Inc.

Supervisor's Office

Scenario 1: Campus-Wide Heating and Cooling



USFS Supervisor's Office - Quincy

Wood-Fired Heating and Cooling

Energy Calculations

Bldgs: 2000, 2001, 2100, 2101, 2200, 2201, 2300, 2301

Project USFS Supervisor's Office - Quincy

Contact Earl Ford
Date 7/9/13



Contact Andrew Haden Phone (503) 706-6187

Email andrew@wisewood.us

Address 1001 SE Water Ave, Suite 255

Portland, OR 97214

•	• •	, .
nas, OR		System Output (MBH) 750
Ford		Fuel Type Conditioned Forest Biomass (<2" <35%MC)

System Description Wood-Fired Heating and Cooling

Workbook Version 3.7.1

Exisiting fossil fuel consumption (MMBtu/HDD) 0.243 Current heating oil use, [gal/yr] 3,500 Max. electrical demand (kW) 0.5 Existing Furnace Eff. 90% Current propane use, [gal/yr] 10,991 Average electrical demand (kW) 0.3 Calculated exisiting heat input (MMBtu/HDD) 0.219 Current heating oil cost, [\$/yr] \$13,125 Annual use (kWhr) 807 \$26,159 Efficiency gains (via EEMs) 0% Estimated reduction in heating oil use 90% Current propane cost, [\$/yr] Wood Boiler Eff. 85.0% Boiler output, high-fire (MBH) 750 Projected wood fuel use, [tons/yr] 116 Heating oil cost, \$/gal. \$3.75 Boiler output, low-fire (MBH) 150 Projected propane use, [gal/yr] 1,662 \$2.38 Projected wood fuel use, [\$/yr] \$11,576 Propane cost, \$/gal. Average boiler output (MBH) 422 Wood MC, wet weight basis 25% Projected heating oil use, [\$/yr] \$3,956 Electricity cost, \$/kWhr 0.17 Projected electricity cost, [\$/yr] \$100.00 Energy of Wood, mmBtu/ton, LHV 12.3 \$65 Wood fuel cost, \$/green ton Fossil fuel cost, \$/mmBtu \$26.42 Energy of heating oil, Btu/gal, HHV 139000 Operating hours per day 12 92000 Wood fuel cost, \$/mmBtu \$8.13 Energy of propane, Btu/gal, HHV Operating hours, yr 2868

<u>Month</u>	Applicable Heating Degree Days [HDD]	Current gross fossil energy consumption. [MMBtu]	Current net space heat energy input [MMBtu]	Projected net space heat input after EEMs [mmBtu/mo]	Projected gross wood energy consumption. [MMBtu]	Projected gross fossil energy consumption. [MMBtu]
September	163	40	36	36	38	12
October	479	116	105	105	111	20
November	793	193	173	173	183	23
December	942	229	206	206	218	23
January	921	224	201	201	213	19
February	762	185	167	167	176	18
March	737	179	161	161	170	13
April	541	131	118	118	125	8
May	328	80	72	72	76	6
June	231	56	51	51	53	3
July	140	34	31	31	32	3
August	126	31	28	28	29	0
Yearly Total, or Avg,	6162	1,498	1,348	1,348	1,424	149

Net fossil energy savings, [MMBtu/yr] 1,349

USFS Supervisor's Office - Quincy

Energy Calculations

Project USFS Supervisor's Office - Quincy


Location Plumas, OR Contact Earl Ford Date 7/9/13



System Description Wood-Fired Heating and Cooling System Output (MBH) 750

Fuel Type Conditioned Forest Biomass (<2" ·

Workbook Version 3.7.1



USFS Supervisor's Office - Quincy Energy Calculations


> Project USFS Supervisor's Office - Quincy Location Plumas, OR Contact Earl Ford Date 7/9/13

Boiler Option Wood-Fired Heating and Cooling Co

Fuel Type Conditioned Forest Biomass (<2" · Workbook Version 3.7.1

System Output (MBH) 750





Boiler Output [MBH]	Fossil Fuel Displaced
34	11%
89	28%
136	39%
177	48%
205	53%
266	64%
341	76%
512	90%
750	90%
1024	86%
1365	82%
1842	70%
2457	47%
3241	5%
4265	0%
5459	0%
7165	0%
10236	0%
13648	0%
17060	0%
20472	0%
23884	0%
27296	0%
30708	0%
34120	0%

USFS Supervisor's Office - Quincy

Energy Calculations -COOLING

Project USFS Supervisor's Office - Quincy **Location** Plumas, OR

Contact Earl Ford
Date 7/9/13




Contact Andrew Haden

System Description Wood-Fired Heating and Cooling
System Output (MBH) 240
Fuel Type Conditioned Forest Biomass (<2" ·

Workbook Version 3.7.1

Phone (503) 706-6187 Email andrew@wisewood.us



USFS Supervisor's Office - Quincy Energy Calculations -COOLING

> Project USFS Supervisor's Office - Quincy Location Plumas, OR Contact Earl Ford


Date 7/9/13

System Description Wood-Fired Heating and Cooling System Output (MBH) 240

Fuel Type Conditioned Forest Biomass (<2" ·

Workbook Version 3.7.1





Chiller Output [MBH]	Fossil Fuel Displaced
17	13%
34	24%
51	34%
68	43%
85	52%
102	60%
119	66%
136	71%
154	75%
171	79%
188	83%
205	85%
222	87%
239	86%
256	87%
273	86%
341	81%
512	62%
682	29%
853	12%
1024	3%
1365	0%
1706	0%
2047	0%
3412	0%



3.7.1

WORKBOOK VERSION:

 Wood-Fired Heating and Cooling
 System Output (MBH)
 750
 ORIG. DATE:
 17-Jun-13

 DRAFT PRELIMINARY SUMMARY COST ESTIMATE
 Contact
 Earl Ford
 REV. DATE:
 09-Jul-13

NO.	ITEM DESCRIPTION	UNIT	QTY	UNIT COST	EST HRS	INSTALL. EQUIPMENT	INSTALL. MATERIALS	INSTALL. LABOR	TOTAL
1	CIVIL/STRUCTURAL:				160	\$10,000	\$30,000	\$20,000	\$60,000
II	MECHANICAL INSTALLATION:				1776	\$30,000	\$570,000	\$140,000	\$740,000
III	PERMITING					\$0	\$10,000	\$0	\$10,000
IV	MISCELLANEOUS:					\$10,000	\$0	\$0	\$10,000
V	ELECTRICAL:				400	\$0	\$30,000	\$30,000	\$60,000
			TOTAL DIREC	T COST:	2336	\$50,000	\$640,000	\$190,000	\$880,000
VI	INDIRECT COSTS: GENERAL CONTRACTOR 0&P ENGINEERING, CONSTRUCTION MANAGEMENT & COMMISSIONING								\$150,000 \$100,000
VII	10% UNLISTED ITEMS ALLOWANCE								\$110,000
VIII	11% CONTINGENCY ALLOWANCE								\$120,000
			TOTAL CAPIT	AL COST:					\$1,360,000
IX	ITEMS NOT IN THIS ESTIMATE COMPLIANCE TESTING ENVIRONMENTAL ENGINEERING STORM WATER SYSTEM ASH OR RESIDUAL DISPOSAL OFF-SITE TAXES NOT INCLUDED								

\$136 5.0

USFS Supervisor's Office - Quincy Proforma Project Financial Statement

30 VP ACCUMULATED CASH FLOW

Project USFS Supervisor's Office - Quincy Location Plumas, OR Contact Earl Ford Date 7/9/13

DEBT SERVICE		
Total Installation Cost		\$ 1,360,000
Grants	0%	\$ -
Debt Leverage		0.0%
Project Equity		100.0%
Loan Amount		\$ -
Amount of Equity		\$ 1,360,000
Annual Rate		5.0%
Term (Years)		30.00

Total/yr

System Description Wood-Fired Heating and Cooling System Output (MBH) 750 Fuel Type Conditioned Forest Biomass (<2* <35%MC) Workbook Version 3.7.1


\$2,400 2%


FUEL COSTS		Fossil Fuel	Wood	Electricity
Unit		(mmBtu)	(mmBtu)	(kWhr)
Cost per unit		\$26.42	\$8.13	\$0.17
Escalation Rate		5.8%	2.0%	3.0%
O&M, WOOD	Labor			Electricity
O&M, WOOD _ Labor (hrs/wk)	Labor 2	Max. elec	trical draw (kW)	Electricity 0.5
			ctrical draw (kW) erage draw (kW)	
Labor (hrs/wk)	2	Av		0.5

Annual cost, pellet boiler Oil boiler, blower, kW Oil boiler, elec. kWh



30 YR ACCUMULATED CASH FLOW	Year 1	Year 2	Year 3	Year 4	Year 5	Year 6	Year 7	Year 8	Year 9	Year 10	Year 15	Year 20	Year 25	Year 30
EXISTING HEATING SYSTEM OPERATING COSTS														
Existing Heating System Replacment Cost	\$ - \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	-	\$	\$	\$ -	\$ -
Projected Heating Oil Cost	\$ 39,574 \$	41.870 \$	44.298 \$	46.868 \$	49.586 \$	52,462 \$	55.505 \$	58.724 \$	62.130 \$	65,733	\$ 87.139	\$ 115.516	\$ 153,134	\$ 203,002
O&M Cost	\$ 1,200 \$	1,224 \$	1,248 \$	1,273 \$	1,299 \$	1,325 \$	1,351 \$	1,378 \$	1,406 \$	1,434	\$ 1,583	\$ 1,748	\$ 1,930	\$ 2,131
Projected Cooling Cost	\$ 5,100 \$	5,253 \$	5,411 \$	5,573 \$	5,740 \$	5,912 \$	6,090 \$	6,272 \$	6,461 \$	6,654	\$ 7,714	\$ 8,943	\$ 10,367	\$ 12,018
TOTAL	\$ 45,874 \$	48,347 \$	50,957 \$	53,714 \$	56,625 \$	59,699 \$	62,946 \$	66,375 \$	69,996 \$	73,822	\$ 86,640	\$ 126,207	\$ 165,431	\$ 217,151
PROPOSED HEATING SYSTEM OPERATING COSTS														
Heating Oil Fuel Cost (Peak and Low Load)	\$ 3,933 \$	4,162 \$	4,403 \$	4,658 \$	4,928 \$	5,214 \$	5,517 \$	5,837 \$	6,175 \$	6,533	\$ 8,661	\$ 11,481	\$ 15,220	\$ 20,177
Wood Fuel Cost	\$ 11,576 \$	11,808 \$	12,044 \$	12,285 \$	12,530 \$	12,781 \$	13,037 \$	13,297 \$	13,563 \$	13,835	\$ 15,275	\$ 16,864	\$ 18,620	\$ 20,558
O&M Cost	\$ 2,400 \$	2,448 \$	2,497 \$	2,547 \$	2,598 \$	2,650 \$	2,703 \$	2,757 \$	2,812 \$	2,868	\$ 3,167	\$ 3,496	\$ 3,860	\$ 4,262
Electrical Cost	\$ 136 \$	140 \$	144 \$	148 \$	153 \$	157 \$	162 \$	167 \$	172 \$	177	\$ 205	\$ 238	\$ 276	\$ 319
Water-Fired Chiller Cooling Costs	\$ 3,795 \$	3,871 \$	3,987 \$	4,107 \$	4,230 \$	4,357 \$	4,488 \$	4,622 \$	4,761 \$	4,904	\$ 5,685	\$ 6,590	\$ 7,640	\$ 8,857
TOTAL	\$ 21,840 \$	22,428 \$	23,075 \$	23,745 \$	24,439 \$	25,159 \$	25,906 \$	26,680 \$	27,483 \$	28,317	\$ 32,992	\$ 38,670	\$ 45,616	\$ 54,172
PROJECT RELATED DEBT														
Beginning Principal Balance	\$ - \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$		\$	\$	\$	\$
Principal Repayments	\$ - \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	-	\$ -	\$ -	\$	\$
Interest Payments	\$ - \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	-	\$ -	\$ -	\$	\$
Ending Principal Balance	\$ - \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$		\$ -	\$ -	\$	\$ -
TOTAL DEBT PAYMENT	\$ - \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	-	\$ -	\$ -	\$ -	\$ -
ANNUAL OPERATING COST SAVINGS (LOSS)	\$ 24,034 \$	25,919 \$	27,883 \$	29,969 \$	32,186 \$	34,540 \$	37,040 \$	39,695 \$	42,513 \$	45,505	\$ 63,445	\$ 87,537	\$ 119,816	\$ 162,979
Cash Investment (equity)	\$ (1,360,000) \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$					
Income (cost savings)	\$ 24,034 \$	25,919 \$	27,883 \$	29,969 \$	32,186 \$	34,540 \$	37,040 \$	39,695 \$	42,513 \$	45,505	\$ 63,445	\$ 87,537	\$ 119,816	\$ 162,979
Net Cash Flow	\$ (1,335,966) \$	25,919 \$	27,883 \$	29,969 \$	32,186 \$	34,540 \$	37,040 \$	39,695 \$	42,513 \$	45,505	\$ 63,445	\$ 87,537	\$ 119,816	\$ 162,979
ACCUMULATED CASH FLOW	\$ (1,335,966) \$	(1,310,047) \$	(1,282,164) \$	(1,252,195) \$	(1,220,010) \$	(1,185,470) \$	(1,148,430) \$	(1,108,735) \$	(1,066,222) \$	(1,020,717)	\$ (741,495)	\$ (354,819)	\$ 175,945	\$ 899,516





Supervisor's Office

Scenario 2: Main Buildings (2000, 2001, 2200, 2301), Heating Only

Wood-Fired Boiler - Main Bldgs Energy Calculations Bldgs: 2000, 2001, 2200, 2301

Project Wood-Fired Boiler - Main Bldgs

Location Plumas, OR
Contact Earl Ford
Date 7/9/13



Contact Andrew Haden Phone (503) 706-6187

Email andrew@wisewood.us

Address 1001 SE Water Ave, Suite 255

Portland, OR 97214

System Description Heat Only System Output (MBH) 500

Fuel Type Conditioned Forest Biomass (<2" <35%MC) Workbook Version 3.7.1

Exisiting fossil fuel consumption (MMBtu/HDD)	0.210	Max. electrical demand (kW)	0.5	Current heating oil use, [gal/yr]	3,500
Existing Furnace Eff.	90%	Average electrical demand (kW)	0.3	Current propane use, [gal/yr]	8,793
Calculated exisiting heat input (MMBtu/HDD)	0.189	Annual use (kWhr)	1065	Current heating oil cost, [\$/yr]	\$13,125
Efficiency gains (via EEMs)	0%	Estimated reduction in heating oil use	91%	Current propane cost, [\$/yr]	\$20,927
Wood Boiler Eff.	85.0%	Boiler output, high-fire (MBH)	500	Projected wood fuel use, [tons/yr]	102
Heating oil cost, \$/gal.	\$3.75	Boiler output, low-fire (MBH)	100	Projected propane use, [gal/yr]	1,217
Propane cost, \$/gal.	\$2.38	Average boiler output (MBH)	336	Projected wood fuel use, [\$/yr]	\$10,188
Electricity cost, \$/kWhr	0.17	Wood MC, wet weight basis	25%	Projected heating oil use, [\$/yr]	\$2,896
Wood fuel cost, \$/green ton	\$100.00	Energy of Wood, mmBtu/ton, LHV	12.3	Projected electricity cost, [\$/yr]	\$85
Fossil fuel cost, \$/mmBtu	\$26.42	Energy of heating oil, Btu/gal, HHV	139000	Operating hours per day	12
Wood fuel cost, \$/mmBtu	\$8.13	Energy of propane, Btu/gal, HHV	92000	Operating hours, yr	3168

<u>Month</u>	Applicable Heating Degree Days [HDD]	Current gross fossil energy consumption. [MMBtu]	Current net space heat energy input [MMBtu]	Projected net space heat input after EEMs [mmBtu/mo]	Projected gross wood energy consumption. [MMBtu]	Projected gross fossil energy consumption. [MMBtu]
September	163	34	31	31	33	9
October	479	101	91	91	97	14
November	793	167	150	150	161	17
December	942	198	178	178	192	17
January	921	194	174	174	187	14
February	762	160	144	144	155	13
March	737	155	139	139	150	10
April	541	114	102	102	110	6
May	328	69	62	62	67	4
June	231	49	44	44	47	3
July	140	29	27	27	29	2
August	126	26	24	24	26	0
Yearly Total, or Avg,	6162	1,295	1,166	1,166	1,253	109

Net fossil energy savings, [MMBtu/yr] 1,186

Wood-Fired Boiler - Main Bldgs

Energy Calculations

Project Wood-Fired Boiler - Main Bldgs Location Plumas, OR


Contact Earl Ford Date 7/9/13

System Description Heat Only System Output (MBH) 500

Fuel Type Conditioned Forest Biomass (<2" <35%MC)

Workbook Version 3.7.1

Contact Andrew Haden Phone (503) 706-6187



Wood-Fired Boiler - Main Bldgs Energy Calculations

Project Wood-Fired Boiler - Main Bldgs
Location Plumas, OR
Contact Earl Ford
Date 7/9/13


Boiler Option Heat Only

System Output (MBH) 500

Fuel Type Conditioned Forest Biomass (<2" <35%MC)

Workbook Version 3.7.1

Contact Andrew Haden Phone (503) 706-6187



Boiler Output [MBH]	Fossil Fuel Displaced
Boiler Output [WBF1]	r coon r doi Biopidoca
34	13%
89	31%
136	44%
177	53%
205	59%
266	71%
341	82%
500	91%
750	88%
1024	85%
1365	76%
1842	61%
2457	18%
3241	0%
4265	0%
5459	0%
7165	0%
10236	0%
13648	0%
17060	0%
20472	0%
23884	0%
27296	0%
30708	0%
34120	0%

Wood-Fired Boiler - Main Bldgs Energy Calculations

> Project Wood-Fired Boiler - Main Bldgs Location Plumas, OR Contact Earl Ford




Contact Andrew Haden Phone (503) 706-6187

Boiler Option Wood-Fired Boiler - Heat Only

System Output (MBH) 500

Fuel Type Conditioned Forest Biomass (<2" <35%MC)

Workbook Version 3.7.1



Deller Order d MADLII	Fassil First Displaced
Boiler Output [MBH]	Fossil Fuel Displaced
	400/
34	13%
89	31%
136	44%
177	53%
205	59%
266	71%
341	82%
500	91%
750	88%
1024	85%
1365	76%
1842	61%
2457	18%
3241	0%
4265	0%
5459	0%
7165	0%
10236	0%
13648	0%
17060	0%
20472	0%
23884	0%
27296	0%
30708	0%
34120	0%



Wood-Fired Boiler - Main Bldgs

System Output (MBH) 500

3.7.2 WORKBOOK VERSION:

Heat Only: Bldgs: 2000, 2001, 2200, 2301

17-Jun-13 ORIG. DATE:

DRAFT PRELIMINARY BUDGETARY SUMMARY COST ESTIMATE Contact Earl Ford REV. DATE: 23-Jul-13

NO.	ITEM DESCRIPTION	UNIT	QTY	UNIT COST	EST HRS	INSTALL. EQUIPMENT	INSTALL. MATERIALS	INSTALL. LABOR	TOTAL
1	CIVIL/STRUCTURAL:				160	\$10,000	\$30,000	\$20,000	\$60,000
II	MECHANICAL INSTALLATION:				1144	\$30,000	\$330,000	\$80,000	\$440,000
Ш	PERMITING					\$0	\$10,000	\$0	\$10,000
IV	MISCELLANEOUS:					\$10,000	\$0	\$0	\$10,000
V	ELECTRICAL:				320	\$0	\$30,000	\$30,000	\$60,000
			TOTAL DIREC	T COST:	1624	\$50,000	\$400,000	\$130,000	\$580,000
VI	INDIRECT COSTS: GENERAL CONTRACTOR 0&P ENGINEERING, CONSTRUCTION MANAGEMENT & COMMISSIONING								\$100,000 \$70,000
VII	10% UNLISTED ITEMS ALLOWANCE								\$70,000
VIII	11% CONTINGENCY ALLOWANCE								\$80,000
			TOTAL CAPIT	AL COST:					\$900,000
IX	ITEMS NOT IN THIS ESTIMATE COMPLIANCE TESTING ENVIRONMENTAL ENGINEERING STORM WATER SYSTEM ASH OR RESIDUAL DISPOSAL OFF-SITE TAXES NOT INCLUDED								

USFS Supervisor's Office - Quincy Proforma Project Financial Statement

Project Wood-Fired Boiler - Main Bldgs Location Plumas, OR Contact Earl Ford Date 7/23/13

DEBT SERVICE		
Total Installation Cos	st \$	900,000
Grants	0% \$	-
Debt Leverage		0.0%
Project Equity		100.0%
Loan Amount	\$	-
Amount of Equity	\$	900,000
Annual Rate		5.0%
Term (Years)		30.00

System Description Heat Only: Bidgs: 2000, 2001, 2200, 2301 System Output (MBH) 500 Fuel Type Conditioned Forest Biomass (<2* <35%MC) Workbook Version 3.7.2

FUEL COSTS	Fossil Fuel	Wood	Electricity			
Unit	(mmBtu)	(mmBtu)	(kWhr)			
Cost per unit	\$26.42	\$8.13	\$0.17			
Escalation Rate	5.8%	2.0%	3.0%			

0&M, W00D	Labor		Electricity
Labor (hrs/wk)	2	Max. electrical draw (kW)	0.5
\$/hr	\$30	Average draw (kW)	0.3
Wk/yr	40	Annual use (kWhr)	1065.1
Total/yr	\$2,400	Annual cost, pellet boiler	\$179
Ann. increase	2%	Oil boiler, blower, kW	5.0
		Oil boiler, elec. kWh	\$0



30 YR ACCUMULATED CASH FLOW		Year 1	Year 2	Year 3	Year 4	Year 5	Year 6	Year 7	Year 8	Year 9	Year 10		Year 15		Year 20	Year 25		Year 30
EXISTING HEATING SYSTEM OPERATING COSTS																		
Existing Heating System Replacment Cost	\$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	-	\$	-	\$	-	\$ -	\$	-
Projected Heating Oil Cost	\$	34,231 \$	36,216 \$	38,317 \$	40,539 \$	42,890 \$	45,378 \$	48,010 \$	50,794 \$	53,740 \$	56,857	\$	75,373	\$	99,918	\$ 132,456	\$	175,590
O&M Cost	\$	1,200 \$	1,224 \$	1,248 \$	1,273 \$	1,299 \$	1,325 \$	1,351 \$	1,378 \$	1,406 \$	1,434	\$	1,583	\$	1,748	\$ 1,930	\$	2,131
TOTAL	\$	35,431 \$	37,440 \$	39,565 \$	41,812 \$	44,189 \$	46,703 \$	49,361 \$	52,173 \$	55,146 \$	58,291	\$	68,857	\$	101,666	\$ 134,386	\$	177,721
PROPOSED HEATING SYSTEM OPERATING COSTS																		
Heating Oil Fuel Cost (Peak and Low Load)	\$	2,880 \$	3,047 \$	3,224 \$	3,411 \$	3,609 \$	3,818 \$	4,039 \$	4,274 \$	4,521 \$	4,784	\$	6,341	\$	8,407	\$ 11,144	\$	14,773
Wood Fuel Cost	\$	10,188 \$	10,392 \$	10,599 \$	10,811 \$	11,028 \$	11,248 \$	11,473 \$	11,703 \$	11,937 \$	12,175	\$	13,443	\$	14,842	\$ 16,386	\$	18,092
O&M Cost	\$	2,400 \$	2,448 \$	2,497 \$	2,547 \$	2,598 \$	2,650 \$	2,703 \$	2,757 \$	2,812 \$	2,868	\$	3,167	\$	3,496	\$ 3,860	\$	4,262
Electrical Cost	\$	179 \$	184 \$	190 \$	196 \$	201 \$	207 \$	214 \$	220 \$	227 \$	233	\$	271	\$	314	\$ 364	\$	422
TOTAL	\$	15,647 \$	16,071 \$	16,510 \$	16,965 \$	17,435 \$	17,923 \$	18,429 \$	18,953 \$	19,497 \$	20,061	\$	23,222	\$	27,058	\$ 31,755	\$	37,549
PROJECT RELATED DEBT																		
Beginning Principal Balance	\$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$		\$	_	\$	-	\$ -	\$	-
Principal Repayments	\$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	-	\$	-	\$	-	\$ -	\$	-
Interest Payments	\$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	-	\$	-	\$	-	\$ -	\$	-
Ending Principal Balance	\$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	-	\$	-	\$	-	\$ -	\$	-
TOTAL DEBT PAYMENT	\$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	-	\$	-	\$	-	\$ -	\$	-
ANNUAL OPERATING COST SAVINGS (LOSS)	\$	19,784 \$	21,369 \$	23,055 \$	24,848 \$	26,754 \$	28,779 \$	30,932 \$	33,220 \$	35,650 \$	38,231	\$	53,735	\$	74,607	\$ 102,631	\$	140,172
Cash Investment (equity)	\$	(900,000) \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$								
Income (cost savings)	\$	19,784 \$	21,369 \$	23,055 \$	24,848 \$	26,754 \$	28,779 \$	30,932 \$	33,220 \$	35,650 \$	38,231	\$	53,735	\$	74,607	\$ 102,631	\$	140,172
Net Cash Flow	\$	(880,216) \$	21,369 \$	23,055 \$	24,848 \$	26,754 \$	28,779 \$	30,932 \$	33,220 \$	35,650 \$	38,231	\$	53,735	\$	74,607	\$ 102,631	\$	140,172
ACCUMULATED CASH FLOW	\$	(880,216) \$	(858,847) \$	(835,792) \$	(810,944) \$	(784,191) \$	(755,411) \$	(724,479) \$	(691,259) \$	(655,610) \$	(617,379)	\$	(381,566)	\$	(52,741)	\$ 401,084	\$	1,022,492
	_											_		_			_	